

RECREATIONAL SPORTS AND IMPORTS (PWS 7100126) SOURCE WATER ASSESSMENT FINAL REPORT

January 29, 2002



State of Idaho Department of Environmental Quality

Disclaimer: This publication has been developed as part of an informational service for the source water assessments of public water systems in Idaho and is based on data available at the time and the professional judgement of the staff. Although reasonable efforts have been made to present accurate information, no guarantees, including expressed or implied warranties of any kind, are made with respect to this publication by the State of Idaho or any of its agencies, employees, or agents, who also assume no legal responsibility for the accuracy of presentations, comments, or other information in this publication. The assessment is subject to modification if new data is produced.

Executive Summary

Under the Safe Drinking Water Act Amendments of 1996, all states are required by the U.S. Environmental Protection Agency to assess every source of public drinking water for its relative sensitivity to contaminants regulated by the Act. This assessment is based on a land use inventory of the designated assessment area and sensitivity factors associated with the wells and aquifer characteristics.

This report, *Source Water Assessment for Recreational Sports and Imports, Idaho Falls, Idaho*, describes the public drinking water system, the boundaries of the zones of water contribution, and the associated potential contaminant sources located within these boundaries. This assessment should be used as a planning tool, taken into account with local knowledge and concerns, to develop and implement appropriate protection measures for this source. **The results should not be used as an absolute measure of risk and they should not be used to undermine public confidence in the water system.**

The Recreational Sports and Imports drinking water system consists of one well source. Although the well has no recorded presence of microbial contaminants, inorganic contaminants excluding nitrate (IOC), synthetic organic contaminants (SOC) or volatile organic contaminants (VOC), the system still has a high susceptibility rating for all four of these parameter categories. The IOC nitrate has been detected, but at levels well below the Maximum Contaminant Level (MCL). The high susceptibility rating is due to a high risk rating in hydrologic sensitivity and system construction as well as numerous potential contaminant sources located within the systems delineation zone. Despite the lack of contamination in the well water, Recreational Sports and Imports should be aware that the potential for contamination is high. Surrounding agricultural land use practices have contributed to the ratings of “High” for County Level Nitrogen Fertilizer Use, County Level Herbicide Use, and Total County Level Ag-Chemical Use. In addition, the delineation for Recreational Sports and Imports crosses an organics priority area for the synthetic organic pesticide atrazine.

This assessment should be used as a basis for determining appropriate new protection measures or re-evaluating existing protection efforts. No matter what ranking a source receives, protection is always important. Whether the source is currently located in a “pristine” area or an area with numerous industrial and/or agricultural land uses that require education and surveillance, the way to ensure good water quality in the future is to act now to protect valuable water supply resources.

For Recreational Sports and Imports, source water protection activities should focus on correcting any deficiencies outlined in the sanitary survey. A sanitary survey is conducted every five years with the purpose of determining the physical condition of a water system’s components and its capacity. Additionally, there should be a focus on implementation of practices aimed at reducing the leaching of agricultural chemicals from agricultural land within the designated source water areas and awareness of the numerous potential contaminant sources in the area. Since much of the designated protection areas are outside the direct control of the Recreational Sports and Imports, it is important to enter into partnerships with state and local agencies, and industry groups. These collaborative agreements are critical to the success of source water protection. All wells should maintain sanitary survey standards regarding wellhead protection.

Due to the time involved with the movement of ground water, source water protection activities should be aimed at long-term management strategies even though these strategies may not yield results in the near term. Source water protection activities for agriculture should be coordinated with the Idaho State Department of Agriculture, the Soil Conservation Commission, the local Soil and Water Conservation District, and the Natural Resources Conservation Service. A community with a fully developed source water protection program will incorporate many strategies. For assistance in developing protection strategies please contact the Idaho Falls Regional Office of the Idaho Department of Environmental Quality or the Idaho Rural Water Association.

SOURCE WATER ASSESSMENT FOR RECREATIONAL SPORTS AND IMPORTS, IDAHO FALLS, IDAHO

Section 1. Introduction - Basis for Assessment

The following sections contain information necessary to understand how and why this assessment was conducted. **It is important to review this information to understand what the ranking of this source means.** A map showing the delineated source water assessment area and the inventory of significant potential sources of contamination identified within that area are attached. The list of significant potential contaminant source categories and their rankings used to develop the assessment also is attached.

Background

Under the Safe Drinking Water Act Amendments of 1996, all states are required by the U.S. Environmental Protection Agency (EPA) to assess every source of public drinking water for its relative susceptibility to contaminants regulated by the Safe Drinking Water Act. This assessment is based on a land use inventory of the delineated assessment area and sensitivity factors associated with the wells and aquifer characteristics.

Level of Accuracy and Purpose of the Assessment

Since there are over 2,900 public water sources in Idaho, there is limited time and resources to accomplish the assessments. All assessments must be completed by May of 2003. An in-depth, site-specific investigation of each significant potential source of contamination is not possible. **Therefore, this assessment should be used as a planning tool, taken into account with local knowledge and concerns, to develop and implement appropriate protection measures for this source. The results should not be used as an absolute measure of risk and they should not be used to undermine public confidence in the water system.**

The ultimate goal of the assessment is to provide data to local communities to develop a protection strategy for their drinking water supply system. The Idaho Department of Environmental Quality (DEQ) recognizes that pollution prevention activities generally require less time and money to implement than treatment of a public water supply system once it has been contaminated. DEQ encourages communities to balance resource protection with economic growth and development. The decision as to the amount and types of information necessary to develop a source water protection program should be determined by the local community based on its own needs and limitations. Wellhead or source water protection is one facet of a comprehensive growth plan, and it can complement ongoing local planning efforts.

Section 2. Conducting the Assessment

General Description of the Source Water Quality

The public drinking water system for the Recreational Sports and Imports is comprised of a single ground water well that serves approximately 75 people through five connections. The well is located in Bonneville County, about one mile northwest of Idaho Falls on Highway 26 (Figure 1).

Though there are no significant water chemistry problems in the ground water, there have been detections in the finished well water of the IOC nitrate at levels below the current MCLs. No VOCs or SOCs have been detected in the well water. However, the delineations do cross an SOC priority area for the pesticide atrazine. In addition, “County Level Nitrogen Fertilizer Use”, “Country Level Herbicide Use”, and “Total County Level Ag-Chemical Use” are high for this area.


Defining the Zones of Contribution – Delineation

The delineation process establishes the physical area around a well that will become the focal point of the assessment. The process includes mapping the boundaries of the zone of contribution into time-of-travel (TOT) zones (zones indicating the number of years necessary for a particle of water to reach a well) for water in the aquifer. DEQ contracted with Washington Group, International (WGI) to perform the delineations using a refined computer model approved by the EPA in determining the 3-year (Zone 1B), 6-year (Zone 2), and 10-year (Zone 3) TOT for water associated with the Eastern Snake River Plain (ESRP) aquifer in the vicinity of the Recreational Sports and Imports Wells. The computer model used site specific data, assimilated by WGI from a variety of sources including the Recreational Sports and Imports operator report, other local area well logs, and hydrogeologic reports (detailed below).

The ESRP is a northeast trending basin located in southeastern Idaho. Ten thousand square miles of the basin are primarily filled with highly fractured layered Quaternary basalt flows of the Snake River Group, which are intercalated with terrestrial and lacustrine sediments along the margins (Garabedian, 1992, p. 5). Individual basalt flows range from 10 to 50 feet in thickness and average 20 to 25 feet (Lindholt, 1996, p. 14). Basalt is thickest in the central part of the eastern plain and thins toward the margins. Whitehead (1992, p. 9) estimates the total thickness of the flows to be as great as 5,000 feet. A thin layer (0 to 100 feet) of windblown and fluvial sediments overlies the basalt.

The plain is bound on the northeast by rocks of the Yellowstone Group (mainly rhyolite) and Idavada Volcanics to the southwest. The Snake River flows along part of the southern boundary and is the only drainage that leaves the plain. Rivers and streams entering the plain from the south are tributary to the Snake River. Other than the Big and Little Wood rivers, rivers entering from the north vanish into the highly transmissive basalts of the Snake River Plain aquifer.

FIGURE 1. Geographic Location of Recreational Sports and Imports



The layered basalts of the Snake River Group host one of the most productive aquifers in the United States. The aquifer is generally considered unconfined, yet it may be locally confined in some areas because of inter-bedded clay and dense unfractured basalt (Whitehead, 1992, p. 26). Whitehead (1992, p. 22) reports that well yields of 2,000 to 3,000 gal/min are common for wells open to less than 100 feet of the aquifer. Lindholm (1996, p. 18) estimates aquifer thickness to range from several hundred feet near the plain's margin to thousands of feet near the center.

The majority of aquifer recharge results from surface water irrigation activities (incidental recharge), which divert water from the Snake River and its tributaries (Ackerman, 1995, p. 4, and Garabedian, 1992, p. 11). Natural recharge occurs through stream losses, direct precipitation, and tributary basin underflow.

Regional ground water flow is to the southwest paralleling the basin (Cosgrove et al., 1999, p. 21; deSonneville, 1972, p. 78; Garabedian, 1992, p. 48; and Lindholm, 1996, p. 23). Ground water flow direction at the local scale is thought to be highly variable due to preferential flow paths through the fractured and layered basalts.

The delineated source water assessment area for the Recreational Sports and Imports well can best be described as an elliptical corridor approximately seventeen miles long and up to 1 mile wide extending to the northeast of Recreational Sports and Imports and ending at the Snake River (Figure 2) near Ririe. The delineation only has the 3-year time-of-travel zone (TOT) and not the 6 and 10-year TOTs because the Snake River is assessed to be the main source of the well's water. The actual data used by WGI in determining the source water assessment delineation areas are available from DEQ upon request.

Identifying Potential Sources of Contamination

A potential source of contamination is defined as any facility or activity that stores, uses, or produces, as a product or by-product, the contaminants regulated under the Safe Drinking Water Act and has a sufficient likelihood of releasing such contaminants at levels that could pose a concern relative to drinking water sources. The goal of the inventory process is to locate and describe those facilities, land uses, and environmental conditions that are potential sources of groundwater contamination. The locations of potential sources of contamination within the delineation areas were obtained by field surveys conducted by DEQ and from available databases.

Land use within the immediate area of the Recreational Sports and Imports wellhead consists of residential and small businesses, while the surrounding area is predominantly irrigated agriculture.

It is important to understand that a release may never occur from a potential source of contamination provided they are using best management practices. Many potential sources of contamination are regulated at the federal level, state level, or both to reduce the risk of release. Therefore, when a business, facility, or property is identified as a potential contaminant source, this should not be interpreted to mean that this business, facility, or property is in violation of any local, state, or federal environmental law or regulation. What it does mean is that the potential for contamination exists due to the nature of the business, industry, or operation. There are a number of methods that water systems can use to work cooperatively with potential sources of contamination, including educational visits and inspections of stored materials. Many owners of such facilities may not even be aware that they are located near a public water supply well.

Contaminant Source Inventory Process

A two-phased contaminant inventory of the study area was conducted in April 2001. The first phase involved identifying and documenting potential contaminant sources within the Recreational Sports and Imports Source Water Assessment Areas (Figures 2 & 3) through the use of computer databases and Geographic Information System maps developed by DEQ. The second, or enhanced, phase of the contaminant inventory involved contacting the operator to identify and add any additional potential sources in the area.

The delineated source water areas encompass corridors of land between the well sites and the Snake River. Both the Well #1 (Table 1, Figure 2) delineation and the Well #2 (Table 1, Figure 3) delineation has one (1) potential contaminant site consisting of the wastewater land application area. Additionally, both delineations cross the Union Pacific Railroad and the Snake River.

Table 1. Potential Contaminant Inventory for Recreational Sports and Imports Well



SITE #	Source Description	TOT Zone ¹ (years)	Source of Information	Potential Contaminants ²
1	UST	3	Database Research	VOC, SOC
2	UST	3	Database Research	VOC, SOC
3	UST	3	Database Research	VOC, SOC
4	UST	3	Database Research	VOC, SOC
5	UST	3	Database Research	VOC, SOC
6	UST	3	Database Research	IOC,VOC, SOC
7	UST	3	Database Research	VOC, SOC
8	UST	3	Database Research	VOC, SOC
9	UST	3	Database Research	IOC,VOC, .SOC
10	UST	3	Database Research	VOC, SOC
11	UST	3	Database Research	VOC, SOC
12	UST	3	Database Research	VOC, SOC
13	UST	3	Database Research	VOC, SOC
14	UST	3	Database Research	IOC,VOC, SOC
15	Dairy	3	Database Research	IOC,SOC,M
16	Sign Company	3	Database Research	IOC,VOC
17	Trucking Company	3	Database Research	VOC, SOC
18	Truck Parts	3	Database Research	VOC, SOC
19	Machine Shop	3	Database Research	IOC,VOC, SOC
20	Satellite Equipment	3	Database Research	IOC,VOC, SOC
21	Marine Motors	3	Database Research	VOC, SOC
22	Cabinet Maker	3	Database Research	IOC,VOC, SOC
23	Seed Company	3	Database Research	IOC, SOC, M
24	Cabinet Maker	3	Database Research	IOC,VOC, SOC
25	Auto Dealer	3	Database Research	VOC, SOC
26	Auto Repair	3	Database Research	IOC,VOC, SOC
27	Auto Dealer	3	Database Research	VOC, SOC
28	Auto Body Repair	3	Database Research	VOC, SOC

SITE #	Source Description	TOT Zone ¹ (years)	Source of Information	Potential Contaminants ²
29	Motorcycle Repair	3	Database Research	VOC, SOC
30	Roofing Company	3	Database Research	IOC,VOC, SOC
31	Stone Products	3	Database Research	IOC,VOC
32	Recycling Center	3	Database Research	VOC
33	Roofing Company	3	Database Research	IOC,VOC, SOC
34	Motorcycle Sales	3	Database Research	IOC,VOC, SOC
35	Motorcycle Sales	3	Database Research	VOC, SOC
36	Plastic Forming	3	Database Research	IOC,VOC, SOC
37	Recycling Center	3	Database Research	IOC,VOC, SOC
38	Farm Equipment	3	Database Research	IOC,VOC, SOC
39	Trucking Company	3	Database Research	IOC,VOC, SOC
40	RV Sales	3	Database Research	VOC, SOC
41	Concrete Contractor	3	Database Research	IOC,VOC, SOC
42	Recycling Center	3	Database Research	VOC
43	Equipment Sales	3	Database Research	IOC,VOC, SOC
44	NPDES	3	Database Research	IOC,M
45	Timber Products	3	Database Research	IOC,VOC, SOC
46	Farm Implements	3	Database Research	IOC,VOC, SOC
47	Heavy Equipment Sales	3	Database Research	IOC,VOC, SOC
48	Sand and Gravel	3	Database Research	IOC
49	Sand and Gravel	3	Database Research	IOC
50	Sand and Gravel	3	Database Research	IOC
51	Recharge Site	3	Database Research	IOC,VOC, SOC
52	Recharge Site	3	Database Research	IOC,VOC, SOC
53	Recharge Site	3	Database Research	IOC,VOC, SOC
54	Potato Processing	3	Database Research	IOC, VOC, SOC, M
55	Highway 26	3	GIS Map	IOC, VOC, SOC, M
56	Irrigation Canal	3	GIS Map	IOC, VOC, SOC, M
57	Union Pacific Railroad	3	GIS Map	IOC, VOC, SOC, M
58	Snake River	3	GIS Map	IOC, VOC, SOC, M

¹ TOT = time-of-travel (in years) for a potential contaminant to reach the wellhead

² IOC = inorganic chemical, VOC = volatile organic chemical, SOC = synthetic organic chemical, M = Microbials

Figure 2. Recreational Sports and Imports Delineation Map and Pontential Contaminant Source Locations



PWS# 7100126
Well #1

Section 3. Susceptibility Analyses

The water system's susceptibility to contamination was ranked as high, moderate, or low risk according to the following considerations: hydrologic characteristics, physical integrity of the well, land use characteristics, and potentially significant contaminant sources. The susceptibility rankings are specific to a particular potential contaminant or category of contaminants. Therefore, a high susceptibility rating relative to one potential contaminant does not mean that the water system is at the same risk for all other potential contaminants. The relative ranking that is derived for each well is a qualitative, screening-level step that, in many cases, uses generalized assumptions and best professional judgement. The following summaries describe the rationale for the susceptibility ranking.

Hydrologic Sensitivity

The hydrologic sensitivity of a well is dependent upon four factors: the surface soil composition, the material in the vadose zone (between the land surface and the water table), the depth to first ground water, and the presence of a 50-foot thick fine-grained zone above the producing zone of the well. Slowly draining soils such as silt and clay typically are more protective of ground water than coarse-grained soils such as sand and gravel. Similarly, fine-grained sediments in the subsurface and a water depth of more than 300 feet protect the ground water from contamination.

Hydrologic sensitivity is high risk for the Recreational Sports and Imports well (Table 2). This is a result of the soils being in the moderately to well-drained class, the fact that the water table is less than 300 feet from the surface, and that there was no well log information detailing whether there are laterally extensive low-permeability units to retard the downward movement of contaminants.

Well Construction

Well construction directly affects the ability of the well to protect the aquifer from contaminants. System construction scores are reduced when information shows that potential contaminants will have a more difficult time reaching the intake of the well. Lower scores imply a system is less vulnerable to contamination. For example, if the well casing and annular seal both extend into a low permeability unit, then the possibility of contamination is reduced and the system construction score goes down. If the highest production interval is more than 100 feet below the water table, then the system is considered to have better buffering capacity. If the wellhead and surface seal are maintained to standards, as outlined in Sanitary Surveys, then contamination down the well bore is less likely. If the well is protected from surface flooding and is outside the 100-year floodplain, then contamination from surface events is reduced.

The Recreational Sports and Imports well has a high risk system construction score. Without well logs, a determination could not be made as to whether the casing and annular seal were completed in low permeability units or whether the highest production zone is greater than 100 feet below the water table.

Without a well log, a determination could not be made as to whether current public water system (PWS) construction standards are being met. Therefore, the assumption is made that this well's casing thickness does not meet current standards. As often is the case, this well may have been in compliance with standards when it was completed. However, current PWS well construction standards are more

stringent. The Idaho Department of Water Resources *Well Construction Standards Rules* (1993) require all PWSs to follow DEQ standards as well. IDAPA 58.01.08.550 requires that PWSs follow the *Recommended Standards for Water Works* (1997) during construction. Table 1 of the *Recommended Standards for Water Works* (1997) lists the required steel casing thickness for various diameter wells. An eight-inch diameter well such as this one should have a casing thickness of 0.322 inch.

Potential Contaminant Source and Land Use

Due largely to the high number of potential contaminants in the well's delineation zone the system rated high risk for IOC's (i.e. nitrates, arsenic), SOC's (i.e. pesticides) and for VOC's (i.e. petroleum products). The system rated moderate risk for microbial contaminants (i.e. bacteria). Agricultural land uses in the delineated source areas also contributed to these ratings.

The well falls within the SOC priority area for the pesticide atrazine and is also in a county with high levels of nitrogen fertilizer use, high herbicide use, and high total ag-chemical use. Fortunately, no significant water chemistry problems have been recorded in the finished well water. Although nitrite is present the well has consistently shown the IOC nitrate at levels below the nitrate MCL of 10 mg/l). No VOC's or SOC's have been detected in the well water.

Final Susceptibility Ranking

A detection above a drinking water standard MCL or a detection of total coliform bacteria or fecal coliform bacteria at the wellhead will automatically give a high susceptibility rating to a well despite the land use of the area because a pathway for contamination already exists. Hydrologic sensitivity and system construction scores are heavily weighted in the final scores. Having multiple potential contaminant sources in the 0 to 3-year time of travel zone (Zone 1B) and agricultural land contribute greatly to the overall ranking. In terms of total susceptibility, the well rates high for all categories due to the factors outlined in the preceding page.

Table 2. Summary of Recreational Sports and Imports Susceptibility Evaluation

Well	Susceptibility Scores ¹									
	Hydrologic Sensitivity	Contaminant Inventory				System Construction	Final Susceptibility Ranking			
		IOC	VOC	SOC	Microbials		IOC	VOC	SOC	Microbials
Well #1	H	H	H	H	M	H	H	H	H	

¹H = High Susceptibility, M = Moderate Susceptibility, L = Low Susceptibility,

IOC = inorganic chemical, VOC = volatile organic chemical, SOC = synthetic organic chemical

Susceptibility Summary

Overall, the Recreational Sports and Imports well rates high risk for all categories. The well-drained nature of the soils, the intense agricultural practices, the high county-wide use of agricultural chemicals, and the existence of local business as potential contaminant sources add up to the high susceptibility ratings.

Though there are no significant water chemistry problems in the ground water, there have been detections in the finished well water of the IOC nitrate at levels below the current MCL. The well falls within the SOC priority area for the pesticide atrazine. No total coliform bacteria, VOCs or SOC's have been detected in the well water.

Section 4. Options for Source Water Protection

The susceptibility assessment should be used as a basis for determining appropriate new protection measures or re-evaluating existing protection efforts. No matter what the susceptibility ranking a source receives, protection is always important. Whether the source is currently located in a “pristine” area or an area with numerous industrial and/or agricultural land uses that require education and surveillance, the way to ensure good water quality in the future is to act now to protect valuable water supply resources.

An effective source water protection program is tailored to the particular local source water protection area. A community with a fully developed source water protection program will incorporate many strategies. For Recreational Sports and Imports, source water protection activities should first focus on correcting any deficiencies outlined in the 1996 sanitary survey. Additionally, there should be a focus on implementation of practices aimed at reducing the leaching of agricultural chemicals from agricultural land within the designated source water areas and awareness of the potential contaminant sources in the area. Since much of the designated protection areas are outside the property boundary of the Recreational Sports and Imports, partnerships with state and local agencies, and industry groups should be established. These collaborative efforts are critical to the success of source water protection. The well should adhere to sanitary survey standards regarding wellhead protection. Additionally, should microbial contamination become a problem, disinfection practices would need to be implemented. Continued vigilance in keeping the wells protected from surface flooding can also keep the potential for contamination reduced. Due to the time involved with the movement of ground water, wellhead protection activities should be aimed at long-term management strategies even though these strategies may not yield results in the short term. Source water protection activities for agriculture should be coordinated with the Idaho Department of Agriculture, the Soil Conservation Commission, the local Soil and Water Conservation District, and the Natural Resources Conservation Service.

Assistance

Public water supplies and others may call the following DEQ offices with questions about this assessment and to request assistance with developing and implementing a local protection plan. In addition, draft protection plans may be submitted to the DEQ office for preliminary review and comments.

Idaho Falls Regional DEQ Office (208) 528-2650

State DEQ Office (208) 373-0502

Website: <http://www2.state.id.us/deq>

Water suppliers serving fewer than 10,000 persons may contact John Bokor, Idaho Rural Water Association, at 1-800-962-3257 for assistance with wellhead protection strategies.

POTENTIAL CONTAMINANT INVENTORY

LIST OF ACRONYMS AND DEFINITIONS

AST (Aboveground Storage Tanks) – Sites with aboveground storage tanks.

Business Mailing List – This list contains potential contaminant sites identified through a yellow pages database search of standard industry codes (SIC).

CERCLIS – This includes sites considered for listing under the **Comprehensive Environmental Response Compensation and Liability Act (CERCLA)**. CERCLA, more commonly known as Superfund is designed to clean up hazardous waste sites that are on the national priority list (NPL).

Cyanide Site – DEQ permitted and known historical sites/facilities using cyanide.

Dairy – Sites included in the primary contaminant source inventory represent those facilities regulated by Idaho State Department of Agriculture (ISDA) and may range from a few head to several thousand head of milking cows.

Deep Injection Well – Injection wells regulated under the Idaho Department of Water Resources generally for the disposal of stormwater runoff or agricultural field drainage.

Enhanced Inventory – Enhanced inventory locations are potential contaminant source sites added by the water system. These can include new sites not captured during the primary contaminant inventory, or corrected locations for sites not properly located during the primary contaminant inventory. Enhanced inventory sites can also include miscellaneous sites added by the Idaho Department of Environmental Quality (DEQ) during the primary contaminant inventory.

Floodplain – This is a coverage of the 100year floodplains.

Group 1 Sites – These are sites that show elevated levels of contaminants and are not within the priority one areas.

Inorganic Priority Area – Priority one areas where greater than 25% of the wells/springs show constituents higher than primary standards or other health standards.

Landfill – Areas of open and closed municipal and non-municipal landfills.

LUST (Leaking Underground Storage Tank) – Potential contaminant source sites associated with leaking underground storage tanks as regulated under RCRA.

Mines and Quarries – Mines and quarries permitted through the Idaho Department of Lands.)

Nitrate Priority Area – Area where greater than 25% of wells/springs show nitrate values above 5mg/l.

NPDES (National Pollutant Discharge Elimination System) – Sites with NPDES permits. The Clean Water Act requires that any discharge of a pollutant to waters of the United States from a point source must be authorized by an NPDES permit.

Organic Priority Areas – These are any areas where greater than 25 % of wells/springs show levels greater than 1% of the primary standard or other health standards.

Recharge Point – This includes active, proposed, and possible recharge sites on the Snake River Plain.

RICRIS – Site regulated under **Resource Conservation Recovery Act (RCRA)**. RCRA is commonly associated with the cradle to grave management approach for generation, storage, and disposal of hazardous wastes.

SARA Tier II (Superfund Amendments and Reauthorization Act Tier II Facilities) – These sites store certain types and amounts of hazardous materials and must be identified under the Community Right to Know Act.

Toxic Release Inventory (TRI) – The toxic release inventory list was developed as part of the Emergency Planning and Community Right to Know (Community Right to Know) Act passed in 1986. The Community Right to Know Act requires the reporting of any release of a chemical found on the TRI list.

UST (Underground Storage Tank) – Potential contaminant source sites associated with underground storage tanks regulated as regulated under RCRA.

Wastewater Land Applications Sites – These are areas where the land application of municipal or industrial wastewater is permitted by DEQ.

Wellheads – These are drinking water well locations regulated under the Safe Drinking Water Act. They are not treated as potential contaminant sources.

NOTE: Many of the potential contaminant sources were located using a geocoding program where mailing addresses are used to locate a facility. Field verification of potential contaminant sources is an important element of an enhanced inventory.

Where possible, a list of potential contaminant sites unable to be located with geocoding will be provided to water systems to determine if the potential contaminant sources are located within the source water assessment area.

References Cited

- Ackerman, D.J., 1995, Analysis of Steady-State Flow and Advective Transport in the Eastern Snake River Plain Aquifer System, Idaho, U.S. Geological Survey Water-Resources Investigations Report 94-4257, I-FY95, 25 p.
- Cosgrove, D.M., G.S. Johnson and S. Laney, 1999, Description of the IDWR/UI Snake River Plain Aquifer Model (SRPAM), Idaho Water Resources Research Institute, 95 p.
- DeSonneville, J.L.J., 1972, Development of a Mathematical Groundwater Model: Water Resources Research Institute, University of Idaho, Moscow, Idaho, 227 p.
- Garabedian, S.P., 1992, Hydrology and Digital Simulation of the Regional Aquifer System, Eastern Snake River Plain, Idaho, U.S. Geological Survey Professional Paper 1408-F, 102 p.
- Great Lakes-Upper Mississippi River Board of State and Provincial Public Health and Environmental Managers, 1997. "Recommended Standards for Water Works."
- Idaho Department of Agriculture, 1998. Unpublished Data.
- Idaho Department of Environmental Quality, 1997. Design Standards for Public Drinking Water Systems. IDAPA 58.01.08.550.01.
- Idaho Department of Water Resources, 1993. Administrative Rules of the Idaho Water Resource Board: Well Construction Standards Rules. IDAPA 37.03.09.
- Lindholm, G.F., 1996, Summary of the Snake River Plain Regional Aquifer-System Analysis in Idaho and Eastern Oregon, U.S. Geological Survey Professional Paper 1408-A, 59 p.
- Whitehead, R.L., 1992, Geohydrological Framework of the Snake River Plain Regional Aquifer System, Idaho and Eastern Oregon, U.S. Geological Survey Professional Paper 1408-B, I-FY92, 32 p.

Attachment A

Recreational Sports and Imports Susceptibility Analysis Worksheets

The final scores for the susceptibility analysis were determined using the following formulas:

- 1) VOC/SOC/IOC Final Score = Hydrologic Sensitivity + System Construction + (Potential Contaminant/Land Use x 0.273)
- 2) 2) Microbial Final Score = Hydrologic Sensitivity + System Construction + (Potential Contaminant/Land Use x 0.375)

Final Susceptibility Scoring:

0 - 5 Low Susceptibility

6 - 12 Moderate Susceptibility

≥ 13 High Susceptibility

1. System Construction		SCORE			
	Drill Date	1/27/76			
	Driller Log Available	NO			
	Sanitary Survey (if yes, indicate date of last survey)	YES	1997		
	Well meets IDWR construction standards	NO	1		
	Wellhead and surface seal maintained	YES	0		
	Casing and annular seal extend to low permeability unit	NO	2		
	Highest production 100 feet below static water level	NO	1		
	Well located outside the 100 year flood plain	NO	1		
Total System Construction Score			5		
2. Hydrologic Sensitivity					
	Soils are poorly to moderately drained	NO	2		
	Vadose zone composed of gravel, fractured rock or unknown	YES	1		
	Depth to first water > 300 feet	NO	1		
	Aquitard present with > 50 feet cumulative thickness	NO	2		
Total Hydrologic Score			6		
3. Potential Contaminant / Land Use - ZONE 1A			IOC Score	VOC Score	SOC Score
	Land Use Zone 1A	IRRIGATED CROPLAND	2	2	2
	Farm chemical use high	YES	2	0	2
	IOC, VOC, SOC, or Microbial sources in Zone 1A	NO	NO	NO	NO
	Total Potential Contaminant Source/Land Use Score - Zone 1A		4	2	4
Potential Contaminant / Land Use - ZONE 1B					
	Contaminant sources present (Number of Sources)	YES	31	47	45
	(Score = # Sources X 2) 8 Points Maximum		8	8	8
	Sources of Class II or III leacheable contaminants or	YES	5	15	3
	4 Points Maximum		4	4	3
	Zone 1B contains or intercepts a Group 1 Area	YES	0	0	2
	Land use Zone 1B	Greater Than 50% Irrigated Agricultural Land	4	4	4
	Total Potential Contaminant Source / Land Use Score - Zone 1B		16	16	17
Potential Contaminant / Land Use - ZONE II					
	Contaminant Sources Present	YES	2	2	2
	Sources of Class II or III leacheable contaminants or	YES	1	1	1
	Land Use Zone II		0	0	0
	Potential Contaminant Source / Land Use Score - Zone II		3	3	3
Potential Contaminant / Land Use - ZONE III					
	Contaminant Source Present	YES	1	1	1
	Sources of Class II or III leacheable contaminants or	YES	1	1	1
	Is there irrigated agricultural lands that occupy > 50% of	NO	0	0	0
	Total Potential Contaminant Source / Land Use Score - Zone III		2	2	2
	Cumulative Potential Contaminant / Land Use Score		25	23	26
4. Final Susceptibility Source Score			16	16	16
5. Final Well Ranking			High	High	High